



Governor Edmund G. Brown Jr.

EXHIBIT B – OUTLINE SPECIFICATIONS DIVISION 2

DIVISION 1 - GENERAL REQUIREMENTS	2
1.1 SUMMARY	2
1.2 RELATED DOCUMENTS	2
1.3 GENERAL PROVISIONS	2
1.4 CONSTRUCTION AND CODE CRITERIA	4
1.5 SUBSTANTIAL COMPLETION AND PROJECT COMPLETION	7
1.6 HAZARDOUS MATERIALS	8
DIVISION 2 - DESIGN REQUIREMENTS	11
2.1 FLOOR CONSTRUCTION AND FINISHES	11
2.2 EXTERIOR WALLS	13
2.3 INTERIOR WALLS AND PARTITIONS	13
2.4 ROOF AND INSULATION	14
2.5 ACOUSTICAL CEILINGS	14
2.6 DOORS	14
2.7 DOOR HARDWARE	15
2.8 MILLWORK	15
2.9 GYPSUM BOARD FINISHES / PAINTING / WALL COVERING / SEALANTS	16
2.10 BUILDING SPECIALTIES	17
2.11 PLUMBING	20
2.12 HEATING, VENTILATING, AND COOLING	20
2.13 ELECTRICAL	22
2.14 PARKING AND PAVING	25

Excerpt from DIVISION 1 - GENERAL REQUIREMENTS

1.1 SUMMARY

A. The Outline Specifications describe minimum standards of quality and performance for premises occupied by the State. Construction methods or materials other than those stated herein may be acceptable if, in the opinion of the State, they provide equal quality and performance.

Excerpt from DIVISION 2 - DESIGN REQUIREMENTS

2.10 BUILDING SPECIALTIES

Page 18 Design Requirements Rev. Mar. 2015

H. Assistive Listening Devices:

1. Lessor shall provide an assistive listening device system for all meeting, conference, quiet, assembly, and gathering rooms. The system shall comply with all accessibility requirements.

2. Occupant Load less than 50:

a. One portable system per floor can be shared between rooms with occupant loads less than 50. The system shall be designed to accommodate the largest room size that is being shared. The portable, wireless FM based system shall include high output acoustic headset(s) such as the Centrum Motiva PFM 360 (**or current model ***) with disposable ear plugs, neck-loop(s), conference microphones and a lockable charger/accessory carry case large enough to hold all equipment. The system shall be hearing aid compatible. Lessor shall provide signage at reception area indicating that the device is available.

3. Occupant Load of 50 or more:

a. Rooms with more than 50 person occupant load and fixed seating must have a fixed assistive listing device system for 4% of the total number of seats in these rooms, but not less than two. Lessor shall provide signage inside each room and in the common hallway and or corridor indicating that the device is available.

***) Current model provided by Centrum Sound: PFM CA**